

NEWCASTLE, ROCKLIN, GOLD HILL CEMETERY DISTRICT

TRUSTEES

Mark Riemer
Rocklin, CA 95677

Grant Kageta
Loomis, CA 95650

Roy Hebard Jr.
Loomis, CA 95650

850 TAYLOR ROAD
NEWCASTLE, CA 95658
(916) 663-4660
FAX (916) 663-4313

TRUSTEES

Gordon Takemoto
Loomis, CA 95650

William Andersen
Loomis, CA 95650

Jeff Forrey
District Manager

Date: 09/10/2025

To: ALL PLAN HOLDERS

RE: Addendum No. 1

This Addendum is applicable to work designated herein and shall be a part of and be included in the Contract Documents for:

**Project: Rocklin Cemetery Pavilion and Restroom Landscape Project
Job#: 2025.1**

This Addendum consists of:

General project questions. Updated project drawings C1 and C2.

Acknowledge receipt of this Addendum in the space provided on the Proposal/Bid form.

1. GENERAL QUESTIONS:

a. Will there be edging next to the rock cobbles?

i. Yes, see updated plans.

b. Will concrete be acceptable for edging?

i. Concrete is the required edging material. For further clarification, concrete edging shall surround the rock cobble channel completely all sides, shall extended to the limits of all grass and bark locations shown on the plans. See updated plans for edging updates.

c. Can you clarify if 2 gallon plants can be used in lieu of 3 gallon plants?

i. See updated plans. Updated plans to install 2 gallon plants where 3 gallon plants were prior specified.

d. *Where will spoils be placed?*

i. **Spoils can be disposed of onsite as directed by the District.**

e. *Can the existing bark be recycled?*

i. **No, the existing bark must be removed completely and disposed onsite as directed by the District. See updated plans.**

f. *Where does the rock lined channel terminate?*

i. **The channel terminates at the location of the existing storm drain outfall at the appropriate location shown on the plans. Contractor shall grade as needed and tie into existing rock lined channel. See updated plan and note.**

g. *Can the Contractor work weekends?*

i. **See specifications section 00 72 13, Article 30, Hours of Work.**

h. *Where will the bid opening occur?*

i. **See specifications section 00 11 16, Notice Inviting Bids. For further clarification, bids shall be submitted at 4090 Kannasto Street, Rocklin, CA 95677.**

i. *Can the piping be schedule 40 in lieu of schedule 80?*

i. **See updated plans.**

END OF ADDENDUM